


Alimentare din BMP existent
amplasat in gang acces teren

Nr. circuit	1	2	3	4	5
Denumire circuit	Protectie la supratensiune	Iluminat 17LL	3LP	5LP	Rezerva
Putere instalata kW	1.00	0.50	1.00		
Putere simultana kW	1.00	0.40	0.80		
Curent nominal A	4.80	1.90	3.80		
Curent nominal A	32	16	16	16	16
Curent reglat A	32	16	16	16	16
Diferential Idn mA	-	30	30	-	-
Putere rupere KA	10	10	10	10	10
Nr. poli	3	2	2	2	2
Contactori A					
Tip cablu	N2XH	N2XH	N2XH	N2XH	
Sectiune mm ²	3x6	3x1.5	3x2.5	3x2.5	
Lungime m					
Tip conductor					
Sect. cond. faza					
Tub de protectie					



Verificator, Expert:	NUME	PROIECTIV DESIGN S.R.L.	CERINTA	REFERAT / EXPERTIZA NR. / DATA
Verificator:				
S. C. PROIECTIV DESIGN S. R. L. ARAD - ROMANIA CUI 35105263 - J2/1102/2015 TEL: 0724284801 / 0729181837 e-mail: proiectivdesign@gmail.com			Denumire proiect: ETAJARE CLADIRE VESTIARE BAZA SPORTIVA Beneficiar: COMUNA ZERIND Amplasament: JUD. ARAD, COM. ZERIND, SAT. ZERIND, CF. 302652 Obiect: INSTALATII ELECTRICE	
ISO 9001			NR 53/2022	
Proiectat: ing. PUI CRISTIAN Desenat: ing. PUI CRISTIAN Verificat: ing. PUI CRISTIAN			Denumire plansa: SCARA % 03.2022 TABLOU T.D. SCHEMA DE DISTRIBUTIE	
			PLANSA IE02	